

## CITY OF AKRON NOTES

### PERMIT INSPECTION NOTES

1. CALL 330-375-2055 TO NOTIFY AND SCHEDULE FOR MANDATORY INSPECTIONS 48 HOURS BEFORE WORK IS TO BEGIN IN THE RIGHT-OF-WAY.
2. ALL PAVEMENT, CURB, AND SIDEWALK TO BE REMOVED SHALL BE SAW CUT FULL DEPTH AT EXISTING CONSTRUCTION JOINTS.
3. ALL SAW CUTTING MUST BE DONE WET, TO CONFORM TO THE OHIO EPA'S FUGITIVE DUST ACT.
4. NO WIRE OR REBAR IN THE CONCRETE WITHIN THE CITY OF AKRON RIGHT-OF-WAY.
5. DOWNSPOUTS SHALL BE INSTALLED TO CONFORM WITH CITY OF AKRON STANDARD DRAWING S-2.
6. ALL RESTORATION WITHIN THE CITY OF AKRON RIGHT-OF-WAY MUST BE COMPLETED TO THE AKRON ENGINEERING BUREAU'S MOST UP TO DATE CONSTRUCTION AND MATERIAL SPECIFICATIONS AND STANDARD DRAWINGS.

### WATER DISTRIBUTION

1. PROPOSED WATER SERVICE, METER AND INSPECTION FEES ARE PAYABLE AT THE CITY OF AKRON PLANS AND PERMITS CENTER, 1030 E. TALLMADGE AVENUE.
2. THE UNDERGROUND WATER LINE MUST BE A MINIMUM OF 1-INCH TYPE K COPPER 4.5 FOOT DEEP AND INSTALLED PER AKRON WATER LINE NOTES 2017-009-02. THIS LINE MUST BE ENCASED IN 4-INCH SCHEDULE 40 PVC CONDUIT UNDER ANY CONCRETE OR ASPHALT SURFACES AND 1-FOOT OUTSIDE OF THE BUILDING FOOTER TO 1 INCH ABOVE FINISHED FLOOR. BE SURE TO MAINTAIN ALL REQUIRED CLEARANCES FROM OTHER UNDERGROUND UTILITIES.
3. CONTACT TOMMY BARNETT FOR A MANDATORY UNDERGROUND WATER LINE INSPECTION PRIOR TO BACKFILLING THE TRENCH AT (330) 812-7822.
4. CONTACT THE UTILITIES BUSINESS OFFICE AND ASK FOR "NEW SITES" TO HAVE YOUR ACCOUNT SETUP AND HANDLE ANY NECESSARY BILLING PAPERWORK AT (330) 375-2554.
5. AT THE 'WATER ENTRY POINT' INSTALL A FULL FLOW 1-INCH BALL VALVE AND STANDARD 5/8" METER SETTING ACCORDING TO AKRON WATER STANDARD 2017-009-05, AVAILABLE ONLINE AT WWW.AKRONOHIO.GOV/WATER THEN SEE THE LINK TO THE RIGHT FOR AWS STANDARD DRAWINGS.
6. ONCE PAYMENT IS MADE AND THE METER SETTING IS CONSTRUCTED, CONTACT THE METER SHOP AT (330) 375-2440.

### SEWER MAINTENANCE

1. WATER SERVICE MUST MAINTAIN A MINIMUM HORIZONTAL SEPARATION OF 10 FEET FROM THE SANITARY SEWER LATERAL.
2. SEWER LATERAL MATERIAL IS 6 INCH SOR 23.5.
3. DOWNSPOUT AND STORM LATERALS ARE NOT PERMITTED TO CONNECT TO CITY INLETS.
4. CONTACT JOE HARBESON WITH SEWER MAINTENANCE 48 HOURS IN ADVANCE FOR MANDATORY INSPECTIONS, 330-375-2666.
5. ANY PROJECT STARTING AFTER JUNE 1, 2021, THE CITY REQUIRES THE CONTRACTOR TO VIDEO EXISTING CONDITIONS PRIOR TO STARTING WORK. TELEVISED VIDEO RECORDING OF ALL SEWERS AND LATERALS THAT ARE WITHIN 100' OF TRENCHING OR TRENCHLESS EXCAVATIONS IS REQUIRED BEFORE AND AFTER WORK. PRE AND POST-CONSTRUCTION VIDEOS ARE REQUIRED TO BE PROVIDED TO THE CITY FOR IT'S RECORD KEEPING.

### STORM WATER POLLUTION PREVENTION PLAN (SWPPP)

1. SILT FENCE IS REQUIRED TO SURROUND THE PROJECT AREA TO KEEP SEDIMENT FROM LEAVING THE PROJECT SITE INTO THE PUBLIC RIGHT-OF-WAY, ADJOINING PROPERTIES, STREAMS, RIVERS, PONDS, LAKES, OR SEWERS.
2. INLET PROTECTION MUST BE PROTECTED ACCORDING TO THE TYPE OF INLET, AND INSTALLED AND IN PLACE BEFORE CONSTRUCTION IS TO BEGIN.
3. SITE SPOILS MUST BE SURROUNDED WITH SILT FENCE UNTIL REMOVED FROM SITE OR 75% OF STABILIZATION VEGETATION HAS GROWN.
4. CONCRETE WASH OUT LOCATION MUST BE LOCATED ON SITE TO COLLECT ALL CONCRETE AND MORTAR EXCESS AND EQUIPMENT CLEAN UP.
5. ALL WASH OUT AND EXCESS CONCRETE AND MORTAR WILL BE CLEANED UP AND REMOVED FROM THE PROJECT SITE AND DISPOSED OF IN PROPER MANNER.

### GUTTERS AND DOWNSPOUTS

1. GUTTERS AND DOWNSPOUTS ARE NOT PERMITTED TO DRAIN OVER THE GROUND.
2. THEY MUST BE CONNECTED TO THE FOLLOWING IN ORDER OF PREFERENCE:
  - a. PUBLIC STORM SEWER.
  - b. COMBINATION SEWER.
  - c. STREET GUTTER OR DITCH.
  - d. NATURAL DRAINAGE WAY (STREAM OR RIVER).
  - e. LEACH WELLS SIZED FOR ONE CUBIT FOOT OF WASHED GRAVEL PER FIFTEEN SQUARE FEET OR ROOF AREA, UNLESS DESIGNED BY A REGISTERED PROFESSIONAL ENGINEER.
3. DOWNSPOUTS ARE NOT ALLOWED TO BE TIED DIRECTLY INTO CATCH BASINS/ INLETS.